


The boil water notice has been lifted, thank you for your patience. We have attached to this letter a copy of the total coliform test results

Laboratory Report**ENDYNE Inc.**
Environmental Laboratories

Woodstock Water Dept, Town of 070644
PO Box 488
Woodstock, VT 05091
Atten: A.J. Wright

PROJECT: WSID 5343 Woodstock Water TCSP

WORK ORDER: 2506-16666

DATE RECEIVED: June 03, 2025

DATE REPORTED: June 04, 2025

SAMPLER: Arthur Wright

VT0005343

001 Site: WSID 5343, 433 Woodstock Rd - SYSTEM EVALUATION Date Sampled: 6/3/25 Time: 14:35

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: SP Compl Ind: N Repl Ind: N

Free Chlorine Residual (Field Result): 0.28 ppm

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Total Coliform	ABSENT	/100 mL	SM20 9223B Colilert	6/3/25 16:47	R MMT	A	
E. coli	ABSENT	/100 mL	SM20 9223B Colilert	6/3/25 16:47	R MMT	A	

002 Site: WSID 5343, 37 Pleasant - SYSTEM EVALUATION Date Sampled: 6/3/25 Time: 14:50

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: SP Compl Ind: N Repl Ind: N

Free Chlorine Residual (Field Result): 0.26 ppm

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Total Coliform	ABSENT	/100 mL	SM20 9223B Colilert	6/3/25 16:47	R MMT	A	
E. coli	ABSENT	/100 mL	SM20 9223B Colilert	6/3/25 16:47	R MMT	A	

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.

The column heading "Lab" denotes the laboratory facility where the testing was performed. "W" designates the Williston, VT lab under NELAC certification ELAP 11263; and ISO/IEC 17025:2017 accredited "R" designates the Lebanon, NH facility under certification NH 2037. This analysis meets NELAC requirements except as noted. Test results are representative of the samples as they were received at the laboratory. Chlorine field results are provided by the client unless otherwise indicated.

Reviewed by:

Alexander J Rakotz
Laboratory Director Lebanon, NH

www.endynelabs.com

160 James Brown Dr., Williston, VT 05495
Ph 802-879-4333 Fax 802-879-7103

ELAP 11263

56 Etna Road, Lebanon, NH 03766
Ph 603-678-4891 Fax 603-678-4893



NH2037